

**RELATIVE HUMIDITY CONVERSION TABLE**

Dry-bulb temperature	Dry-bulb temperature minus wet-bulb temperature, °C									
	1	2	3	4	5	6	7	8	9	10
10°C	88	77	66	55	44	34	24	15	6	
11°C	89	78	67	56	46	36	27	18	9	
12°C	89	78	68	58	48	39	29	21	12	
13°C	89	79	69	59	50	41	32	22	15	7
14°C	90	79	70	60	51	42	34	26	18	10
15°C	90	80	71	61	53	44	36	27	20	13
16°C	90	81	71	63	54	46	38	30	23	15
17°C	90	81	72	64	55	47	40	32	25	18
18°C	91	82	73	65	57	49	41	34	27	20
19°C	91	82	74	65	58	40	43	36	29	22
20°C	91	83	74	66	59	51	44	37	31	24
21°C	91	83	75	67	60	53	46	39	32	26
22°C	92	83	76	68	61	54	47	40	34	28
23°C	92	84	76	69	62	55	48	42	36	30
24°C	92	84	77	69	62	56	49	43	37	31
25°C	92	84	77	70	63	57	50	44	39	33
26°C	92	85	78	71	64	58	51	46	40	34
27°C	92	85	78	71	65	58	52	47	41	36
28°C	93	85	78	72	65	59	53	48	42	37
29°C	93	86	79	72	66	60	54	49	43	38
30°C	93	86	79	73	67	61	55	50	44	39